

Company

Address
City
Phone
Other

JOB TITLE

JOB NO.
CALCULATED BY
CHECKED BY

SHEET NO.
DATE
DATE

TU08 Ver 2010.07.23

TILT-UP CONCRETE WALL (ACI 318-08)

www.struware.com

DESCRIPTION: ACI 551.2R-10 example B.1

PANEL PROPERTIES		LOADING		12" STRIP WIDTH	
Panel Height: Lc =	29.5 ft	Conc Weight =	150.0 pcf	Lateral Loading	plf Ms (lb)
Total Panel Thickness =	6.25 in	fc =	4.0 ksi	Wind Pressure =	17.0 psf 17.0 1849.3
Reveal Thickness =	0.00 in	fy =	60.0 ksi	Seismic Factor =	0.000 0.0 0.0
Structural Thickness: h =	6.25 in	Lt wt conc factor		Use this seismic moment instead :	
Strip Width: b =	180.0 in	(NW=1, LW=.75)	1.00	Vertical Loading	
Cover to Ext Vert Bar =	0.75 in			SDS =	0.000
Vert Bar Location :	Centered	Min Defl ratio =	150	Uniform Vertical Loading	eccentricity plf Ms (lb)
Bar Depth: d =	3.125 in			Strip wt midht =	1270 plf 0.000 in 1270 0.0
Vertical Bar Size =	# 6			Dead Load =	0 plf 3.000 in 0 0.0
Vertical Bar Spacing =	11.3 in			Floor Live Load =	0 plf 3.000 in 0 0.0
As =	0.469 in ² /ft			Roof Live Load =	0 plf 3.000 in 0 0.0
Parapet Height =	1.50 ft			Roof Snow Load =	0 plf 3.000 in 0 0.0
Opening Properties		Horizontal Reinforcing:		Concentrated Vertical Loading	eccentricity
Opening Width =	0.00 ft	As =	0.0020 Ag	Opening wt midht =	0.0 k 0.000 in 0 0.0
EL Top of Opening =	0.00 ft	Centered	Each Face	Dead Load =	7.2 k 3.000 in 480 60.0
EL Bottom Opening =	0.00 ft	#4@ 15.7	#4@ 18.0	Floor Live Load =	0.0 k 3.000 in 0 0.0
Opening Material Wt =	10.0 psf	#5@ 18.0	#5@ 18.0	Roof Live Load =	7.5 k 3.000 in 500 62.5
Opng Conc thickness =	6.25 in			Roof Snow Load =	0.0 k 3.000 in 0 0.0
				Garage, assembly or LL>100psf:	<input type="radio"/> Roofs that don't shed snow: <input checked="" type="radio"/>
				All Others:	<input checked="" type="radio"/> All Others: <input type="radio"/>

STRENGTH

	1.4D	1.2D +1.6L	1.2D +0.5L	1.2D +0.8W	1.2D +0.5Lr	1.2D +0.7S	0.9D	(0.9-.2SDs)D	
Mua (lb) =	84.0	103.3	172.0	1651.4	3062.1	72.0	3012.9	54.0	
Pu (lb) =	2449.3	2349.4	2899.4	2899.4	2349.4	2099.4	1574.6	1574.6	COMPRESSION OKAY
Pu /Ag (psi) =	32.7	31.3	38.7	38.7	31.3	28.0	21.0	21.0	
0.06Fc (psi) =	240.0	240.0	240.0	240.0	240.0	240.0	240.0	240.0	
Ase (in²) =	0.51	0.51	0.52	0.52	0.51	0.50	0.50	0.50	
Ec (ksi) =	3605	3605	3605	3605	3605	3605	3605	3605	
n =	8.04	8.04	8.04	8.04	8.04	8.04	8.04	8.04	
a (in) =	0.749	0.747	0.760	0.760	0.747	0.741	0.728	0.728	
c (in) =	0.882	0.879	0.895	0.895	0.879	0.872	0.856	0.856	
Icr (in⁴) =	23.4	23.3	23.6	23.6	23.3	23.2	23.0	23.0	
εr =	0.0076	0.0077	0.0075	0.0075	0.0077	0.0078	0.0079	0.0079	
φ =	0.900	0.900	0.900	0.900	0.900	0.900	0.900	0.900	
Ig (in⁴) =	244.1	244.1	244.1	244.1	244.1	244.1	244.1	244.1	
yt (in) =	3.12	3.12	3.12	3.12	3.12	3.12	3.12	3.12	
fr (psi) =	474.3	474.3	474.3	474.3	474.3	474.3	474.3	474.3	
Mcr (lb) =	3088.2	3088.2	3088.2	3088.2	3088.2	3088.2	3088.2	3088.2	
Mu (lb) =	170.0	201.0	423.9	4070.1	5959.7	127.8	4499.8	80.7	
Capacity: φMn (lb) =	6306.8	6289.0	6386.8	6386.8	6289.0	6244.3	6150.2	6150.2	STRENGTH OKAY

DEFLECTION

	D	D +0.5L	D +0.5Lr	D +0.7W	D+0.70W (1+.105SDs)D	0.6D	(0.6-.14SDs)D		
Msa (lb) =	60.0	91.3	91.3	1354.5	1385.7	60.0	1885.3	36.0	
Ps (lb) =	1749.5	1999.5	1999.5	1749.5	1999.5	1749.5	1049.7	1049.7	
Δcr (in) =	0.550	0.550	0.550	0.550	0.550	0.550	0.550	0.550	
Δn (in) =	13.028	13.015	13.090	13.090	13.015	12.980	12.907	12.907	
Ma (lb) =	61.6	94.0	94.0	1390.6	1387.4	61.6	1915.1	36.6	
Δs (in) =	0.011	0.017	0.017	0.247	0.010	0.011	0.341	0.007	
Defl Ratio =	L / 9999	L / 9999	L / 9999	L / 1430	L / 9999	L / 9999	L / 1039	L / 9999	DEFLECTION OKAY

Service Load Combinations:
ACI 318 Commentary
Load Combinations:

Company
Address
City
Phone
Other


JOB TITLE
JOB NO. SHEET NO.
CALCULATED BY DATE
CHECKED BY DATE

TU08 Ver 2010.07.23

TILT-UP CONCRETE WALL (ACI 318-08)

www.struware.com

DESCRIPTION: ACI 551.2R-10 example B.1



PANEL ELEVATION