

Company

Address
City
Phone
Other

JOB TITLE

JOB NO.
CALCULATED BY
CHECKED BY

SHEET NO.
DATE
DATE

TU08 Ver 2010.07.23

TILT-UP CONCRETE WALL (ACI 318-08)

www.struware.com

DESCRIPTION: ACI 551.2R-10 example B.2

PANEL PROPERTIES		LOADING		12" STRIP WIDTH	
Panel Height: Lc = 29.5 ft	Conc Weight = 150.0 pcf	Lateral Loading		plf	Ms (lb)
Total Panel Thickness = 8.75 in	fc = 4.0 ksi	Wind Pressure = 17.0 psf		38.3	4160.9
Reveal Thickness = 0.00 in	fy = 60.0 ksi	Seismic Factor = 0.000		0.0	0.0
Structural Thickness: h = 8.75 in	Lt wt conc factor (NW=1, LW=.75) = 1.00	Use this seismic moment instead : 0.0			
Strip Width: b = 48.0 in	Min Defl ratio = 150	Vertical Loading			
Cover to Ext Vert Bar = 0.75 in		S _{DS} = 0.000			
Vert Bar Location : Centered		Uniform Vertical Loading	eccentricity	plf	Ms (lb)
Bar Depth: d = 4.375 in		Strip wt midht = 1777 plf	0.000 in	1777	0.0
Vertical Bar Size = # 6		Dead Load = 0 plf	3.000 in	0	0.0
Vertical Bar Spacing = 6.9 in		Floor Live Load = 0 plf	3.000 in	0	0.0
As = 0.770 in ² /ft		Roof Live Load = 0 plf	3.000 in	0	0.0
Parapet Height = 1.50 ft		Roof Snow Load = 0 plf	3.000 in	0	0.0
Opening Properties	Horizontal Reinforcing:	Concentrated Vertical Loading	eccentricity		
Opening Width = 10.00 ft	As = 0.0020 Ag	Opening wt midht = 8.8 k	0.000 in	2188	0.0
EL Top of Opening = 15.00 ft	Centered Each Face	Dead Load = 4.5 k	3.000 in	1125	140.6
EL Bottom Opening = 0.00 ft	#4@ 11.2 #4@ 18.0	Floor Live Load = 0.0 k	3.000 in	0	0.0
Opening Material Wt = 0.0 psf	#5@ 17.5 #5@ 18.0	Roof Live Load = 4.7 k	3.000 in	1175	146.9
Opng Conc thickness = 8.75 in		Roof Snow Load = 0.0 k	3.000 in	0	0.0
		Garage, assembly or LL>100psf: <input type="radio"/>	Roofs that don't shed snow: <input checked="" type="radio"/>		
		All Others: <input checked="" type="radio"/>	All Others: <input type="radio"/>		

STRENGTH

	1.4D	1.2D +1.6L	1.2D +0.5L	1.2D +0.8W	1.2D +1.6W	1.2D +0.5L	1.2D +0.5L	0.9D	
		+0.5Lr	+1.6Lr	+1.6Lr	+0.5Lr	+0.7S	+1.6W	+1.0E	
Mua (lb) =	196.9	242.2	403.8	3732.5	6899.6	168.8	6784.0	126.6	
Pu (lb) =	7125.8	6695.3	7987.8	7987.8	6695.3	6107.8	4580.9	4580.9	
Pu /Ag (psi) =	67.9	63.8	76.1	76.1	63.8	58.2	43.6	43.6	COMPRESSION OKAY
0.06Fc (psi) =	240.0	240.0	240.0	240.0	240.0	240.0	240.0	240.0	
Ase (in ²) =	0.89	0.88	0.90	0.90	0.88	0.87	0.85	0.85	
Ec (ksi) =	3605	3605	3605	3605	3605	3605	3605	3605	
n =	8.04	8.04	8.04	8.04	8.04	8.04	8.04	8.04	
a (in) =	1.307	1.296	1.328	1.328	1.296	1.282	1.244	1.244	
c (in) =	1.537	1.525	1.562	1.562	1.525	1.508	1.464	1.464	
Icr (in ⁴) =	72.1	71.8	72.7	72.7	71.8	71.4	70.2	70.2	
ε _r =	0.0055	0.0056	0.0054	0.0054	0.0056	0.0057	0.0060	0.0060	
φ =	0.900	0.900	0.900	0.900	0.900	0.900	0.900	0.900	
Ig (in ⁴) =	669.9	669.9	669.9	669.9	669.9	669.9	669.9	669.9	
yt (in) =	4.37	4.37	4.37	4.37	4.37	4.37	4.37	4.37	
fr (psi) =	474.3	474.3	474.3	474.3	474.3	474.3	474.3	474.3	
Mcr (lb) =	6052.8	6052.8	6052.8	6052.8	6052.8	6052.8	6052.8	6052.8	
Mu (lb) =	376.6	440.6	859.7	7947.1	12552.6	287.6	9902.2	184.7	
Capacity: φMn (lb) =	14881.3	14782.0	15079.0	15079.0	14782.0	14646.1	14289.7	14289.7	STRENGTH OKAY

DEFLECTION

	D	D	D	D+0.70W (1+.105Sds)D				
	D	+0.5L	+0.5Lr	+0.7W	+0.50L	+0.7E	0.6D	
		or 0.5Lr	or 0.5S		or 0.50Lr	+0.5(L+S)	(0.6-.14Sds)D	
Msa (lb) =	140.6	214.1	214.1	3053.2	3126.7	140.6	4245.3	84.4
Ps (lb) =	5089.8	5677.3	5677.3	5089.8	5677.3	5089.8	3053.9	3053.9
Δcr (in) =	0.393	0.393	0.393	0.393	0.393	0.393	0.393	0.393
Δn (in) =	9.966	9.943	10.011	10.011	9.943	9.910	9.823	9.823
Ma (lb) =	144.6	220.8	220.8	3139.6	3131.4	144.6	4383.4	85.8
Δs (in) =	0.009	0.014	0.014	0.204	0.010	0.009	0.543	0.006
Defl Ratio =	L / 9999	L / 9999	L / 9999	L / 1738	L / 9999	L / 9999	L / 652	L / 9999

Service Load Combinations:
ACI 318 Commentary Load Combinations:

DEFLECTION OKAY

Company

Address

City

Phone

Other

JOB TITLE

JOB NO.

CALCULATED BY

CHECKED BY

SHEET NO.

DATE


DATE

TU08 Ver 2010.07.23

TILT-UP CONCRETE WALL (ACI 318-08)

www.struware.com

DESCRIPTION: ACI 551.2R-10 example B.2



PANEL ELEVATION